

GOVERNMENT OF BIHAR

P. H. Division, Begusarai

DISTRICT LEVEL DRINKING WATER TESTING LABORATORY, BEGUSARAI.

Report No. :- WQ/ T/ 01/ 2007 -3183. Dt. 25.05.2023

Ref No :- SJPS/29/23. Dt: 20.05.2023

Sample Collected by - Ravi Shankar Prasad Singh.

Date of Sampling - 20.05.2023

Sample received on - 22.05.2023

Source of Sample :- Boring (Treated Water).

PHYSICO-CHEMICAL TEST REPORT

Sl. No.	SITE NAME	Physico-Chemical Parameters (mg/l) ppm												
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Bacteriological (H-S)	Arsenic	Fluoride
1	St. Joseph Public School Affiliation No-330225 Behind G.D College, Kali Nager, Begusarai.	7.5	BDL	462	300	276	66	18	72	262	0.12	(-)ve	BDL	0.52
Desirable Limit*		6.5-8.5	1 NTU	-	500mg/l	300mg/l	75mg/l	30mg/l	250mg/l	200mg/l	1.0mg/l	(+, -)	0.01mg/l	1.0mg/l
Permissible Limit* in absence of alternate source		NR	5 NTU	-	2000mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	500mg/l	NR		NR	1.5mg/l

Note:-

*(1) Drinking Water Specification Second Revision -IS:10500:2012,

*(2) BDL = Below Detection Limit,

*(3) Testing Methods are taken by APHA 23rd Edition 2017,

*(4) NR = No Relaxation

(5) The result are reported based on materials received. Sample will be destroyed after 10 days from the date of issue of the certificate unless otherwise specified.

Lab Incharge
P.H. Division Begusarai.



कार्यालय, नगर निगम, बेगूसराय।

ज्ञापांक...1632.../दिनांक 03/10/2023...


स्वच्छता प्रमाण-पत्र

सेंट जोसेफ पब्लिक स्कूल काली नगर वार्ड नं० 22, जी०डी० कॉलेज के पीछे बेगूसराय के द्वारा स्वच्छता को लेकर औचक निरीक्षण सी०एम०एम०, कर दारोगा सफाई निरीक्षक, नगर निगम, बेगूसराय के प्रतिवेदनानुसार कराया गया।

जांच में यह पाया गया कि साफ-सफाई एवं स्वच्छता के प्रति सेंट जोसेफ पब्लिक स्कूल (संस्थान) जागरूक है। प्रत्येक वर्ग कक्ष के लिए डस्टबीन लगा है। वर्ग कक्ष से लेकर जगह-जगह प्रांगण में साफ-सफाई बेहतर देखी गयी। शौचालय का बेहतर रख-रखाव एवं स्वच्छ पेय जल की उचित व्यवस्था देखी गयी।

हम आशा करते हैं कि आगे भी स्वच्छता के प्रति सेंट जोसेफ पब्लिक स्कूल इसी तरह सजग रहेगा। हम संस्थान के उज्ज्वल भविष्य की कामना करते हैं।




नगर आयुक्त,
नगर निगम, बेगूसराय।